

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015718
DATE: 01/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Optimum
CODE: 1742-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Optimum Window Manufacturing, Corp. 28 Canal Street Ellenville, NY 12428	Series "RTS-430i French Doors" Steel Outswing French Doors Configuration: XX Glazing: Monolithic-3/16" Heat Strengthened Glass/0.090" SGP Interlayer/3/16" Heat Strengthened Glass Frame: W-1829mm(72") H-2438mm(96") DLO: W-805mm(31.69") H-2297mm(90.44")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94 ASTM E283-04/12 ASTM E330-14 ASTM E331-00/09	Design Pressure: ±3112 Pa (±65 psf) Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf) Large Missile Impact Rated

Product Tested By: Blackwater Technical Services, Inc.
Report No: BT-OPM-21-001A/BT-OPM-21-001B
Expiration Date: **October 31, 2026**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com