

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015724  
DATE: 01/25/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Exeter  
CODE: 2898-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>Exeter Architectural Products</b><br><b>47052 Conrad E. Anderson Street</b><br><b>Hammond, Louisiana 70401</b> | <b>Series "Storm Shield"</b><br><b>Aluminum Frame Hurricane Shutter</b><br><b>(w/Stainless or Galvanized Steel Screen)</b><br><br>Configuration: XX<br><br>Frame: W-2610mm(102.75") H-1915mm(75.38")<br>Panel: W-1219mm(48") H-1829mm(72") |

| SPECIFICATION                          | PRODUCT RATING   |
|--|--|
| TAS 201-94<br>TAS 202-94<br>TAS 203-94 | <b>Design Pressure: +50/-50 psf</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: Architectural Testing Incorporated  
Report No: A1022.01-109-18  
Expiration Date: August 31, 2027

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)