

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015724.01
DATE: 01/25/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Exeter
CODE: 2898-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Exeter Architectural Products 47052 Conrad E. Anderson Street Hammond, Louisiana 70401	Series "Storm Shield" Aluminum Frame Hurricane Shutter (w/Stainless or Galvanized Steel Screen) Configuration: XX Frame: W-3245mm(127.75") H-2134mm(84") Panel: W-1524mm(60") H-2134mm(84")

SPECIFICATION	PRODUCT RATING
TAS 201-94 TAS 202-94 TAS 203-94	Design Pressure: +60/-60 psf Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated
Report No: A0200.01-109-18
Expiration Date: August 31, 2027

A handwritten signature in black ink, appearing to be "Shelby".

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com