## NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015725

**DATE:** 01/25/2023

**CERTIFICATION PROGRAM:** Structural

**COMPANY:** Exeter

**CODE:** <u>2898-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <a href="www.namicertification.com">www.namicertification.com</a>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Exeter Architectural Products</b>	Series "Face Mount"
47052 Conrad E. Anderson Street	Aluminum Frame Triple Venting Mesh
Hammond, Louisiana 70401	Storm Screen
	(w/Stainless Steel Screen)
	Configuration: XXX
	Frame: W-3924mm(154.50") H-1829mm(72")
	Panel: W-1257mm(49.50") H-1783mm(70.19")

SPECIFICATION	PRODUCT RATING
TAS 201-94 TAS 202-94 TAS 203-94	Design Pressure: +40/-35 psf Large Missile Impact Rated

Product Tested By: Architectural Testing Incorporated

Report No: B9681.01-109-18 Expiration Date: July 31, 2027

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com