

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015727
DATE: 01/25/2023
CERTIFICATION PROGRAM: Man Housing
COMPANY: Wausau Supply
CODE: 1644-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Wausau Supply Company, Inc. 8011 Technology Drive Schofield, WI 54476	3' 0" x 7' 0" Glazed Steel Edge Steel Door in Wood Jamb Inswing Side Hinged Door Configuration: X Frame: W-953mm(37.5") H-2178mm(85.75") Panel: W-908mm(35.75") H-2108mm(83") DLO: W-539mm(21.22") H-1603mm(63.13")

SPECIFICATION	PRODUCT RATING
AAMA 1702.2-95 Federal Manufactured Home Construction & Safety Standard 3280.405	Manufactured Housing-Passed Wind Zone III Design Wind Pressure Rating: +46/-46 psf <small>(Wind Zone III - All areas except 3'0" from endwall or sidewall)</small>

Product Tested By: Testing Evaluation Laboratories, Inc.
Report No: TEL 01123581
Expiration Date: October 31, 2024

Administrator's Signature: _____


NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com