

Notice of Product Certification

CERTIFICATION NO.: 1228-016

COMPANY: Portes et Fenetres Varin Inc.

INITIAL CERTIFICATION DATE: February 8, 2023

CODE: 1228-1

REVISION DATE: N/A

EXPIRATION DATE: August 30, 2027

REPORT NUMBER: SPL22001-6-C_HSOX-H

PRODUCT SIMULATED BY: Veridis Solutions Inc.

SPECIFICATION: CSA A440.2-19

AIR LEAKAGE REPORT NO.: AI-04137-E1 Rev.1

PRODUCT/SERIES NAME: Couissant Simple Hybride - 9020D OPERATOR TYPE: HSOX

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1228-016-0001-01	GL, 3mm_7/8_GCl-arg95-8071, ms	0.082(#3)	1.67	0.52	0.58	0.5	32
1228-016-0002-01	GL, 3mm_7/8_GCl-arg95-8071, ms, Grids<1"	0.082(#3)	1.67	0.46	0.52	0.5	29
1228-016-0003-01	GL, 3mm_7/8_GCl-arg95-8071, ms, Grids>1"	0.082(#3)	1.67	0.41	0.46	0.5	26
1228-016-0004-01	GL, 3mm_7/8_STCl-arg95-8071, ms	0.082(#3)	1.67	0.54	0.59	0.5	34
1228-016-0005-01	GL, 3mm_7/8_STCl-arg95-8071, ms, Grids<1"	0.082(#3)	1.67	0.49	0.52	0.5	31
1228-016-0006-01	GL, 3mm_7/8_STCl-arg95-8071, ms, Grids>1"	0.082(#3)	1.67	0.43	0.46	0.5	27
1228-016-0007-01	GL, 3mm_7/8_GCl-arg95-8071, sp	0.082(#3)	1.62	0.52	0.58	0.5	34
1228-016-0008-01	GL, 3mm_7/8_GCl-arg95-8071, sp, Grids<1"	0.082(#3)	1.62	0.46	0.52	0.5	30
1228-016-0009-01	GL, 3mm_7/8_GCl-arg95-8071, sp, Grids>1"	0.082(#3)	1.62	0.41	0.46	0.5	27
1228-016-0010-01	GL, 3mm_7/8_STCl-arg95-8071, sp	0.082(#3)	1.62	0.54	0.59	0.5	35
1228-016-0011-01	GL, 3mm_7/8_STCl-arg95-8071, sp, Grids<1"	0.082(#3)	1.62	0.49	0.52	0.5	32
1228-016-0012-01	GL, 3mm_7/8_STCl-arg95-8071, sp, Grids>1"	0.082(#3)	1.62	0.43	0.46	0.5	28
1228-016-0013-01	BF, 3mm_7/8_GCl-arg95-8071, ms	0.082(#3)	1.65	0.52	0.58	0.5	33
1228-016-0014-01	BF, 3mm_7/8_GCl-arg95-8071, ms, Grids<1"	0.082(#3)	1.65	0.46	0.52	0.5	29
1228-016-0015-01	BF, 3mm_7/8_GCl-arg95-8071, ms, Grids>1"	0.082(#3)	1.65	0.41	0.46	0.5	27
1228-016-0016-01	BF, 3mm_7/8_STCl-arg95-8071, ms	0.082(#3)	1.65	0.54	0.59	0.5	34
1228-016-0017-01	BF, 3mm_7/8_STCl-arg95-8071, ms, Grids<1"	0.082(#3)	1.65	0.49	0.52	0.5	31
1228-016-0018-01	BF, 3mm_7/8_STCl-arg95-8071, ms, Grids>1"	0.082(#3)	1.65	0.43	0.46	0.5	28
1228-016-0019-01	BF, 3mm_7/8_GCl-arg95-8071, sp	0.082(#3)	1.61	0.52	0.58	0.5	34
1228-016-0020-01	BF, 3mm_7/8_GCl-arg95-8071, sp, Grids<1"	0.082(#3)	1.61	0.46	0.52	0.5	30

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1228-016-0021-01	BF, 3mm_7/8_GCI-arg95-8071, sp, Grids>1"	0.082(#3)	1.61	0.41	0.46	0.5	27
1228-016-0022-01	BF, 3mm_7/8_STCI-arg95-8071, sp	0.082(#3)	1.61	0.54	0.59	0.5	35
1228-016-0023-01	BF, 3mm_7/8_STCI-arg95-8071, sp, Grids<1"	0.082(#3)	1.61	0.49	0.52	0.5	32
1228-016-0024-01	BF, 3mm_7/8_STCI-arg95-8071, sp, Grids>1"	0.082(#3)	1.61	0.43	0.46	0.5	29
1228-016-0025-01	GL, 3mm_7/8_PCI-arg97-PTLX, ss	0.082(#3)	1.60	0.54	0.58	0.5	35
1228-016-0026-01	GL, 3mm_7/8_PCI-arg97-PTLX, ss, Grids<1"	0.082(#3)	1.60	0.48	0.51	0.5	32
1228-016-0027-01	GL, 3mm_7/8_PCI-arg97-PTLX, ss, Grids>1"	0.082(#3)	1.60	0.43	0.45	0.5	29
1228-016-0028-01	GL, 3mm_7/8_SDCI-arg97-PTLX, ss	0.082(#3)	1.60	0.56	0.58	0.5	36
1228-016-0029-01	GL, 3mm_7/8_SDCI-arg97-PTLX, ss, Grids<1"	0.082(#3)	1.60	0.50	0.52	0.5	33
1228-016-0030-01	GL, 3mm_7/8_SDCI-arg97-PTLX, ss, Grids>1"	0.082(#3)	1.60	0.44	0.46	0.5	29
1228-016-0031-01	GL, 3mm_7/8_PCI-arg97-PTLX, ms	0.082(#3)	1.66	0.54	0.58	0.5	34
1228-016-0032-01	GL, 3mm_7/8_PCI-arg97-PTLX, ms, Grids<1"	0.082(#3)	1.66	0.48	0.51	0.5	30
1228-016-0033-01	GL, 3mm_7/8_PCI-arg97-PTLX, ms, Grids>1"	0.082(#3)	1.66	0.43	0.45	0.5	27
1228-016-0034-01	BF, 3mm_7/8_PCI-arg97-PTLX, ss	0.082(#3)	1.58	0.54	0.58	0.5	36
1228-016-0035-01	BF, 3mm_7/8_PCI-arg97-PTLX, ss, Grids<1"	0.082(#3)	1.58	0.48	0.51	0.5	32
1228-016-0036-01	BF, 3mm_7/8_PCI-arg97-PTLX, ss, Grids>1"	0.082(#3)	1.58	0.43	0.45	0.5	29
1228-016-0037-01	BF, 3mm_7/8_SDCI-arg97-PTLX, ss	0.082(#3)	1.58	0.56	0.58	0.5	37
1228-016-0038-01	BF, 3mm_7/8_SDCI-arg97-PTLX, ss, Grids<1"	0.082(#3)	1.58	0.50	0.52	0.5	33
1228-016-0039-01	BF, 3mm_7/8_SDCI-arg97-PTLX, ss, Grids>1"	0.082(#3)	1.58	0.44	0.46	0.5	30
1228-016-0040-01	BF, 3mm_7/8_PCI-arg97-PTLX, ms	0.082(#3)	1.64	0.54	0.58	0.5	34
1228-016-0041-01	BF, 3mm_7/8_PCI-arg97-PTLX, ms, Grids<1"	0.082(#3)	1.64	0.48	0.51	0.5	31
1228-016-0042-01	BF, 3mm_7/8_PCI-arg97-PTLX, ms, Grids>1"	0.082(#3)	1.64	0.43	0.45	0.5	28

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.
 4794 George Washington Memorial Hwy.
 Hayes, VA 23072
 Tel.: (804) 684-5124
 nami@namiinc.com
 namicertification.com