

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015733-R1  
DATE: 02/13/2023  
CERTIFICATION PROGRAM: Fire  
COMPANY: Kempsville  
CODE: 2587-1  
REVISION DATE: 12/12/2023  
EXPIRATION DATE: 02/28/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Kempsville Building Materials Corp.</b> <b>3300 Business Center Drive</b> <b>Chesapeake, VA 23323</b>	<b>FyreWerks FC-20</b> <b>20 Minute Positive Pressure</b> <b>Side-Hinged Door</b>  Manufacturer Specific Fire Doors for Single & Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single & Double Swing Only  <b>Single Maximum Size: 4'0" x 8'0"</b> <b>Double Maximum Size: 7'0" x 8'0"</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>UL 10(b) (2009)</b> <b>CAN/ULC-S104 (2015)</b> <b>UL 10(c) (2015)</b> <b>NFPA 252 (2012)</b>	<b>20 Minute-Positive Pressure w/Hose Stream</b> <b>Category B Door-Additional Edge Seal Required</b> <b>For Use in Category C Frame</b> <small>(or may also be installed in Category C-Proprietary in accordance with individual manufacturer's listing)</small>

TEST REPORT
<b>Intertek Test Report No: 3073306, 3084820, 3144298COQ-003, 3159384COQ-002, 3156802COQ-004, 3181657COQ-006, 3179089COQ-003, 10015449MID-001, 102627269MID-001, 103096847MID-001</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)