## **NOTICE OF PRODUCT CERTIFICATION**



<b>CERTIFICATION NO:</b>
DATE:
<b>CERTIFICATION PROGRAM:</b>
COMPANY:
CODE:

NI015734	
02/14/2023	
Structural	
Loewen	
1862-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
Loewen	"Metal Clad Inswing 60T Combo Mullion"	
77 Highway 52 West	<b>Combination Aluminum/Wood Glazed</b>	
Steinbach, Manitoba R5G 1B2	Inswing Side-Hinged Door Assembly	
	(w/Fixed Panel & Transom)	
	Configuration: O/OX Glazing: Insulating Glass (Tempered)	
	Frame: W-2517mm(99") H-4331mm(170")	
	Panel: W-1219mm(48") H-3048mm(120")	
	DLO: W-1065mm(41.93") H-2859mm(112.56")	
	Transom:W-2448mm(96") H-1169mm(46")	

SPECIFICATION	PRODUCT RATING
AAMA 450-10 ASTM E283-04 ASTM E547-00 ASTM E330-02	<b>Design Pressure: ±1200 Pa(±25 psf)</b> Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Report No: Expiration Date:

UL Laboratory Canada, Inc. AI-05646-E3 November 30, 2026

Shi

Administrator's Signature:

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 nami@namiinc.com