

Notice of Product Certification

CERTIFICATION NO.: 2901-003
INITIAL CERTIFICATION DATE: March 7, 2023
REVISION DATE: N/A
REPORT NUMBER: AJR22110670-c
SPECIFICATION: CSA A440.2-19

COMPANY: AJR Window Technologies
CODE: 2901-1
EXPIRATION DATE: January 18, 2028
PRODUCT SIMULATED BY: WSP
AIR LEAKAGE REPORT NO.: 21-06-B0082-6N

PRODUCT/SERIES NAME: High Fixed **OPERATOR TYPE:** FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2901-003-0001-01	CCI-arg97-180, ss	0.068(#3)	1.50	0.52	0.60	0.0	37
2901-003-0001-02	CCI-arg97-180, ss, Grids<1"	0.068(#3)	1.50	0.47	0.53	0.0	34
2901-003-0002-01	GCl-arg97-8071, ss	0.082(#3)	1.52	0.54	0.61	0.0	38
2901-003-0002-02	GCl-arg97-8071, ss, Grids<1"	0.082(#3)	1.52	0.49	0.54	0.0	35
2901-003-0003-01	180-arg97-i89, ss	0.068(#2) 0.149(#4)	1.26	0.48	0.59	0.0	40
2901-003-0003-02	180-arg97-i89, ss, Grids<1"	0.068(#2) 0.149(#4)	1.26	0.43	0.52	0.0	37
2901-003-0004-01	CCI-arg97-CCI-arg97-180, ss	0.068(#5)	1.13	0.47	0.55	0.0	42
2901-003-0004-02	CCI-arg97-CCI-arg97-180, ss, Grids<1"	0.068(#5)	1.13	0.42	0.49	0.0	40
2901-003-0005-01	GCl-arg97-GCl-arg97-8071, ss	0.082(#5)	1.14	0.49	0.55	0.0	43
2901-003-0005-02	GCl-arg97-GCl-arg97-8071, ss, Grids<1"	0.082(#5)	1.14	0.44	0.49	0.0	40
2901-003-0006-01	180-arg97-CCI-arg97-180, ss	0.068(#2, #5)	0.91	0.43	0.53	0.0	45
2901-003-0006-02	180-arg97-CCI-arg97-180, ss, Grids<1"	0.068(#2, #5)	0.91	0.38	0.47	0.0	42
2901-003-0007-01	8071-arg97-GCl-arg97-8071, ss	0.082(#2, #5)	0.93	0.45	0.54	0.0	46
2901-003-0007-02	8071-arg97-GCl-arg97-8071, ss, Grids<1"	0.082(#2, #5)	0.93	0.40	0.48	0.0	43
2901-003-0008-01	SPCl-arg90-SG400-arg90-VCl, iu	0.113(#3)	1.24	0.51	0.55	0.0	42
2901-003-0008-02	SPCl-arg90-SG400-arg90-VCl, iu, Grids<1"	0.113(#3)	1.24	0.45	0.49	0.0	39
2901-003-0009-01	SPCl-arg90-SPCl-arg90-SG400, iu	0.113(#5)	1.20	0.52	0.56	0.0	44
2901-003-0009-02	SPCl-arg90-SPCl-arg90-SG400, iu, Grids<1"	0.113(#5)	1.20	0.46	0.50	0.0	40
2901-003-0010-01	VCl-arg90-SB60, iu	0.035(#3)	1.49	0.37	0.55	0.0	29
2901-003-0010-02	VCl-arg90-SB60, iu, Grids<1"	0.035(#3)	1.49	0.33	0.49	0.0	26
2901-003-0011-01	VCl-arg90-VCl-arg90-SB60, iu	0.035(#5)	1.12	0.34	0.50	0.0	35
2901-003-0011-02	VCl-arg90-VCl-arg90-SB60, iu, Grids<1"	0.035(#5)	1.12	0.31	0.44	0.0	33
2901-003-0012-01	SB60-arg90-SB60-arg90-VCl, iu	0.035(#2, #4)	0.90	0.24	0.44	0.0	34
2901-003-0012-02	SB60-arg90-SB60-arg90-VCl, iu, Grids<1"	0.035(#2, #4)	0.90	0.22	0.39	0.0	33

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com