

# Notice of Product Certification

CERTIFICATION NO.: 2901-004  
 INITIAL CERTIFICATION DATE: March 7, 2023  
 REVISION DATE: N/A  
 REPORT NUMBER: AJR22110670-d  
 SPECIFICATION: CSA A440.2-19

COMPANY: AJR Window Technologies  
 CODE: 2901-1  
 EXPIRATION DATE: January 18, 2028  
 PRODUCT SIMULATED BY: WSP  
 AIR LEAKAGE REPORT NO.: 21-06-B0082-13N

PRODUCT/SERIES NAME: Low Fixed OPERATOR TYPE: FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2870-004-0001-01	CCI-arg97-180, ss	0.068(#3)	1.53	0.59	0.68	0.0	41
2870-004-0001-02	CCI-arg97-180, ss, Grids<1"	0.068(#3)	1.53	0.54	0.61	0.0	38
2870-004-0002-01	GCl-arg97-8071, ss	0.082(#3)	1.55	0.61	0.69	0.0	41
2870-004-0002-02	GCl-arg97-8071, ss, Grids<1"	0.082(#3)	1.55	0.55	0.62	0.0	38
2870-004-0003-01	180-arg97-i89, ss	0.068(#2) 0.149(#4)	1.25	0.54	0.67	0.0	44
2870-004-0003-02	180-arg97-i89, ss, Grids<1"	0.068(#2) 0.149(#4)	1.25	0.49	0.60	0.0	41
2870-004-0004-01	CCI-arg97-CCI-arg97-180, ss	0.068(#5)	1.11	0.53	0.62	0.0	46
2870-004-0004-02	CCI-arg97-CCI-arg97-180, ss, Grids<1"	0.068(#5)	1.11	0.48	0.56	0.0	43
2870-004-0005-01	GCl-arg97-GCl-arg97-8071, ss	0.082(#5)	1.13	0.55	0.63	0.0	47
2870-004-0005-02	GCl-arg97-GCl-arg97-8071, ss, Grids<1"	0.082(#5)	1.13	0.50	0.57	0.0	44
2870-004-0006-01	180-arg97-CCI-arg97-180, ss	0.068(#2, #5)	0.86	0.48	0.60	0.0	49
2870-004-0006-02	180-arg97-CCI-arg97-180, ss, Grids<1"	0.068(#2, #5)	0.86	0.44	0.54	0.0	47
2870-004-0007-01	8071-arg97-GCl-arg97-8071, ss	0.082(#2, #5)	0.88	0.51	0.62	0.0	50
2870-004-0007-02	8071-arg97-GCl-arg97-8071, ss, Grids<1"	0.082(#2, #5)	0.88	0.46	0.55	0.0	47
2870-004-0008-01	SPCI-arg90-SG400-arg90-VCl, iu	0.113(#3)	1.24	0.57	0.62	0.0	46
2870-004-0008-02	SPCI-arg90-SG400-arg90-VCl, iu, Grids<1"	0.113(#3)	1.24	0.52	0.56	0.0	43
2870-004-0009-01	SPCI-arg90-SPCI-arg90-SG400, iu	0.113(#5)	1.20	0.59	0.63	0.0	48
2870-004-0009-02	SPCI-arg90-SPCI-arg90-SG400, iu, Grids<1"	0.113(#5)	1.20	0.53	0.57	0.0	44
2870-004-0010-01	VCl-arg90-SB60, iu	0.035(#3)	1.51	0.42	0.62	0.0	31
2870-004-0010-02	VCl-arg90-SB60, iu, Grids<1"	0.035(#3)	1.51	0.38	0.56	0.0	29
2870-004-0011-01	VCl-arg90-VCl-arg90-SB60, iu	0.035(#5)	1.11	0.39	0.57	0.0	38
2870-004-0011-02	VCl-arg90-VCl-arg90-SB60, iu, Grids<1"	0.035(#5)	1.11	0.35	0.51	0.0	36
2870-004-0012-01	SB60-arg90-SB60-arg90-VCl, iu	0.035(#2, #4)	0.85	0.28	0.50	0.0	38
2870-004-0012-02	SB60-arg90-SB60-arg90-VCl, iu, Grids<1"	0.035(#2, #4)	0.85	0.25	0.45	0.0	36

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)  
[namicertification.com](http://namicertification.com)