

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI014830.02  
**DATE:** 03/15/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Moss  
**CODE:** 206-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Moss Supply Company</b> <b>5001 North Graham Street</b> <b>Charlotte, NC 28269</b>	<b>Series "7300 NC/7330 REPL PD2"</b> <b>Vinyl Sliding Glass Door</b> <b>(New Construction Frame 1130-PD-T200)</b> <b>(Replacement Frame 1100-PD-T200)</b>  Configuration: XO Glazing: Insulating Glass (Tempered)  Frame: W-2426mm(95.50") H-2426mm(95.50") Panel: W-1213mm(47.75") H-2348mm(92.44") DLO: W-1016mm(40") H-2151mm(84.69")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class LC-PG50 2426 x 2426 (96 x 96)-SD</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC  
Report No: N4851.02-501-44  
Expiration Date: **April 30, 2026**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)