

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI014830.04
DATE: 03/15/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Moss
CODE: 206-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Moss Supply Company 5001 North Graham Street Charlotte, NC 28269	Series "7300 NC/7330 REPL PD4" Vinyl Sliding Glass Door (New Construction Frame 1130-PD-T200) (Replacement Frame 1100-PD-T200) Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-4864mm(191.50") H-2426mm(95.50") Panel: W-1213mm(47.75") H-2350mm(92.50") DLO: W-1016mm(40") H-2151mm(84.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG50 4877 x 2426 (192 x 96)-SD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: N4854.02-501-44
Expiration Date: **January 31, 2027**

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com