

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015741
DATE: 03/08/2023
CERTIFICATION PROGRAM: Structural
COMPANY: WARREN
CODE: 2890-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Warren Windows & Doors (Guangdong) Co., Ltd. 7 East Industrial Road, Songxia Ind. Park Shishan, Nahai District Foshan Guangdong, China 528200	Series "Architect Series Fixed Window" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1524mm(60") H-1524mm(60") DLO: W-1440mm(56.69") H-1440mm(56.69")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG50 1524 x 1524 (60 x 60)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)

Product Tested By: Intertek, PLC
Report No: 221110001SHF-002
Expiration Date: January 31, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com