

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015742
DATE: 03/08/2023
CERTIFICATION PROGRAM: Structural
COMPANY: WARREN
CODE: 2890-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Warren Windows & Doors (Guangdong) Co., Ltd. 7 East Industrial Road, Songxia Ind. Park Shishan, Nahai District Foshan Guangdong, China 528200	Series "Architect Series Tilt & Turn Window" Aluminum Dual Action Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1219mm(48") H-1828mm(72") Sash: W-1162mm(45.76") H-1772mm(69.76") DLO: W-1040mm(40.95") H-1650mm(64.95")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG40 1219 x 1828 (48 x 72)-DAW Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.00 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: 221110001SHF-005
Expiration Date: **January 31, 2027**

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com