

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015743
DATE: 03/08/2023
CERTIFICATION PROGRAM: Structural
COMPANY: WARREN
CODE: 2890-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Warren Windows & Doors (Guangdong) Co., Ltd. 7 East Industrial Road, Songxia Ind. Park Shishan, Nahai District Foshan Guangdong, China 528200	Series "Push Out Series Casement Window" Aluminum Casement Window Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-914mm(36") H-1524mm(60") Sash: W-791mm(31.16") H-1401mm(55.16") DLO: W-653mm(25.72") H-1263mm(49.72")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19	Class CW-PG50 914 x 1524 (36 x 60)-C Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.00 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek, PLC
Report No: 221110001SHF-003
Expiration Date: January 31, 2027

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com