

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015747.01  
**DATE:** 03/14/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Polaris  
**CODE:** 213-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Polaris Windows and Doors</b> <b>500 Victoria Road</b> <b>Austintown, Ohio 44515</b>	<b>Series "7505/8605/3205"</b> <b>Vinyl Fixed Window</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1219mm(48") H-1219mm(48") DLO: W-1092mm(43") H-1092mm(43")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b>	<b>Class R-PG50 1219 x 1219 (48 x 48)-FW</b> <b>Design Pressure: 2400 Pa (50 psf)</b> <b>Positive Design Pressure: 2880 Pa (60 psf)</b> <b>Negative Design Pressure: 2880 Pa (60 psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b>

Product Tested By: Molimo, LLC  
Report No: 12179.01-109-12  
Expiration Date: February 28, 2027

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)