

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015747
DATE: 03/14/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Polaris
CODE: 213-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Polaris Windows and Doors 500 Victoria Road Austintown, Ohio 44515	Series "7505/8605/3205" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1905mm(75") H-1905mm(75") DLO: W-1778mm(70") H-1778mm(70")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11	Class LC-PG50 1905 x 1905 (75 x 75)-FW Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Molimo, LLC
Report No: 12179.01-109-12
Expiration Date: **February 28, 2027**

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com