

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015752  
**DATE:** 03/20/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Wincore  
**CODE:** 1640-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Wincore Window Company, LLC</b> <b>250 Staunton Turnpike</b> <b>Parkersburg, WV 26104</b>	<b>Series "400/500/5400 SH Zero Mull"</b> <b>Vinyl Mullled Single Hung Window</b> <b>(New Construction &amp; Replacement Install)</b>  Configuration: O/XO/X Glazing: Insulating Glass (Annealed)  Frame: W-1829mm(72")      H-1829mm(72") Sash: W-857mm(33.75")      H-889mm(35") DLO: W-797mm(31.38")      H-829mm(32.63")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class LC-PG40 1829 x 1829* (72 x 72*)-H</b> <b>Design Pressure: ±1920 Pa (±40 psf)</b> <b>Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf)</b>

Product Tested By: Intertek PLC  
Report No: P4732.01-109-44/P4731.01-109-44  
Expiration Date: **March 31, 2027**

Administrator's Signature:  \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)