

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015762
DATE: 03/27/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Hoelscher
CODE: 1765-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Hoelscher Weatherstrip Manufacturing Company, Inc. 10111 Houston Oaks Drive Houston, TX 77064	Series "HWS 6080 4 Lite" Glazed 4 Lite Fiberglass Inswing Double Side-Hinged Doors Configuration: XX Glazing: Insulated Glass (Tempered) Frame: W-1892mm(74.50") H-2483mm(97.75") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-295mm(11.63") H-787mm(31")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14	DP: +60/-55 psf

Product Tested By: Intertek, PLC
Report No: P1701.01-801-44
Expiration Date: September 30, 2026

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com