

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015767
DATE: 03/28/2023
CERTIFICATION PROGRAM: Fire
COMPANY: JELD-WEN
CODE: 1822-1
EXPIRATION DATE: 02/28/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	"HDF/MDF Skin w/Warm Springs Core" Wood Side Hinged Door w/X20 Adhesive Manufacture Specific Fire Doors for Single Swing Installation in 45-Minute Locations 1/2" Minimum Latch Throw Single Swing Only Maximum Size: 35.81" x 83.5" Minimum Thickness: 1.75"

SPECIFICATION	PRODUCT RATING
UL 10(c) (2021)	45 Minute-Positive Pressure With Hose Stream Category B- Additional Edge Sealing System Required

TEST REPORT
Intertek Test Report No: 105199609MID-007

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com