

# Notice of Product Certification

CERTIFICATION NO.: 1270-008  
INITIAL CERTIFICATION DATE: April 5, 2023  
REVISION DATE: N/A  
REPORT NUMBER: SPL22002-6\_C\_VSSH\_1  
SPECIFICATION: CSA A440.2-19

COMPANY: Rusco Manufacturing  
CODE: 1270-1  
EXPIRATION DATE: January 26, 2028  
PRODUCT SIMULATED BY: Veridis Solutions  
AIR LEAKAGE REPORT NO.: AI-04422-E1 Rev.1

PRODUCT/SERIES NAME: PVC Single Hung | 9420      OPERATOR TYPE: VSSH

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1270-008-0001-01	3mm_7/8_8071-arg95-IS20, im	0.082(#2) 0.198(#4)	1.43	0.49	0.59	0.4	36
1270-008-0002-01	3mm_7/8_8071-arg95-IS20, im, Grids<1"	0.082(#2) 0.198(#4)	1.43	0.44	0.53	0.4	33
1270-008-0003-01	3mm_7/8_8071-arg95-IS20, im, Grids>1"	0.082(#2) 0.198(#4)	1.43	0.39	0.47	0.4	30

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)  
[namicertification.com](http://namicertification.com)