

Notice of Product Certification

CERTIFICATION NO.: 1279-003
INITIAL CERTIFICATION DATE: April 5, 2023
REVISION DATE: N/A
REPORT NUMBER: TPE23001-1-C_FIXD-b
SPECIFICATION: CSA A440.2-19

COMPANY: Fenetres Nordist Engr.
CODE: 1279-1
EXPIRATION DATE: February 9, 2028
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-03626-B2

PRODUCT/SERIES NAME: S-3120 Pano

OPERATOR TYPE: FIXD

| Product Number | Manufacturer Product Code | Emissivity (Surface #) | U-Factor (Metric) | SHGC(w) | Visible Transmittance (VT) | Air Leakage Average (L75) | Energy Rating |
|------------------|--|------------------------|-------------------|---------|----------------------------|---------------------------|---------------|
| 1279-003-0001-01 | 3mm_7_8_CLR_arg95_LoE 180#3, ss | 0.068(#3) | 1.55 | 0.59 | 0.67 | 0.0 | 40 |
| 1279-003-0002-01 | 3mm_7_8_CLR_arg95_LoE 180#3, ss, Grids <1" | 0.068(#3) | 1.55 | 0.53 | 0.60 | 0.0 | 37 |
| 1279-003-0003-01 | 3mm_1_1_4_CLR_arg95_CLR_arg95_LoE 180#5, ss | 0.068(#5) | 1.16 | 0.53 | 0.62 | 0.0 | 45 |
| 1279-003-0004-01 | 3mm_1_1_4_CLR_arg95_CLR_arg95_LoE 180#5, ss, Grids <1" | 0.068(#5) | 1.16 | 0.47 | 0.55 | 0.0 | 42 |
| 1279-003-0005-01 | 3mm_1_1_4_LoE 180#2_arg95_CLR_arg95_LoE 180#5, ss | 0.068(#2, #5) | 0.92 | 0.48 | 0.59 | 0.0 | 48 |
| 1279-003-0006-01 | 3mm_1_1_4_LoE 180#2_arg95_CLR_arg95_LoE 180#5, ss, Grids <1" | 0.068(#2, #5) | 0.92 | 0.43 | 0.53 | 0.0 | 45 |
| 1279-003-0007-01 | 3mm_7_8_CLR_arg95_8071#3, ss | 0.082(#3) | 1.57 | 0.61 | 0.68 | 0.0 | 41 |
| 1279-003-0008-01 | 3mm_7_8_CLR_arg95_8071#3, ss, Grids <1" | 0.082(#3) | 1.57 | 0.55 | 0.61 | 0.0 | 37 |
| 1279-003-0009-01 | 3mm_1_1_4_CLR_arg95_CLR_arg95_8071#5, ss | 0.082(#5) | 1.18 | 0.55 | 0.62 | 0.0 | 46 |
| 1279-003-0010-01 | 3mm_1_1_4_CLR_arg95_CLR_arg95_8071#5, ss, Grids <1" | 0.082(#5) | 1.18 | 0.49 | 0.56 | 0.0 | 42 |
| 1279-003-0011-01 | 3mm_1_1_4_8071#2_arg95_CLR_arg95_8071#5, ss | 0.082(#2, #5) | 0.94 | 0.50 | 0.61 | 0.0 | 48 |
| 1279-003-0012-01 | 3mm_1_1_4_8071#2_arg95_CLR_arg95_8071#5, ss, Grids <1" | 0.082(#2, #5) | 0.94 | 0.45 | 0.54 | 0.0 | 45 |

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Administrator's Signature:



National Accreditation & Management Institute, Inc.

4794 George Washington Memorial Hwy.

Hayes, VA 23072

Tel.: (804) 684-5124

nami@namiinc.com

namicertification.com

