

# Notice of Product Certification

**CERTIFICATION NO.:** 1279-005  
**INITIAL CERTIFICATION DATE:** April 5, 2023  
**REVISION DATE:** N/A  
**REPORT NUMBER:** TPE23002-1\_C\_VSSH-a  
**SPECIFICATION:** CSA A440.2-19

**COMPANY:** Fenetres Nordist Engr.  
**CODE:** 1279-1  
**EXPIRATION DATE:** February 23, 2028  
**PRODUCT SIMULATED BY:** Veridis Solutions  
**AIR LEAKAGE REPORT NO.:** NCTL-110-17749-1

**PRODUCT/SERIES NAME:** Guillotine Simple S5100    **OPERATOR TYPE:** VSSH

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1279-005-0001-01	3mm_3-4_GCl-arg95-8071#3, ss	0.082(#3)	1.68	0.57	0.64	0.5	35
1279-005-0002-01	3mm_3-4_GCl-arg95-8071#3, ss, Grids <1"	0.082(#3)	1.68	0.51	0.57	0.5	32

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S.M.D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
nami@namiinc.com  
namicertification.com