

Notice of Product Certification

CERTIFICATION NO.: 1279-007
INITIAL CERTIFICATION DATE: April 5, 2023
REVISION DATE: N/A
REPORT NUMBER: TPE23002-1_C_HSOX-a
SPECIFICATION: CSA A440.2-19

COMPANY: Fenetres Nordist Engr.
CODE: 1279-1
EXPIRATION DATE: February 23, 2028
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: NCTL-110-17748-1

PRODUCT/SERIES NAME: Coulissant Simple S5150 **OPERATOR TYPE:** HSOX

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
1279-007-0001-01	3mm_3_4_GCI-arg95-8071#3, ss	0.082(#3)	1.67	0.57	0.64	0.4	36
1279-007-0002-01	3mm_3_4_GCI-arg95-8071#3, ss, Grids <1"	0.082(#3)	1.67	0.51	0.57	0.4	32

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com