

Notice of Product Certification

CERTIFICATION NO.: 2908-002
INITIAL CERTIFICATION DATE: April 18, 2023
REVISION DATE: N/A
REPORT NUMBER: AMR23001-1_C_FIXD_r01
SPECIFICATION: CSA A440.2-19

COMPANY: AMRO Aluminium, Inc.
CODE: 2908-1
EXPIRATION DATE: February 9, 2028
PRODUCT SIMULATED BY: Veridis Solutions Inc.
AIR LEAKAGE REPORT NO.: AI-04716-C2

PRODUCT/SERIES NAME: Isobar 200 Fixed

OPERATOR TYPE: FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2908-002-0001-01	3mm_SDCI-arg97-SDCI-arg97-8071, sw	0.082(#5)	1.30	0.58	0.63	0.2	45
2908-002-0002-01	3mm_SDCI-arg97-SDCI-arg97-8071, tps	0.082(#5)	1.34	0.58	0.63	0.2	44

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. M.', is written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com