

Notice of Product Certification

CERTIFICATION NO.: 2915-001
INITIAL CERTIFICATION DATE: April 27, 2023
REVISION DATE: N/A
REPORT NUMBER: SKR21001-5-C_CSSV-a
SPECIFICATION: CSA A440.2-19

COMPANY: Globaltek Home Improvements, Ltd.
CODE: 2915-1
EXPIRATION DATE: June 25, 2026
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: L13-651-3359

PRODUCT/SERIES NAME: SGI016 (1600 Series) Casement OPERATOR TYPE: CSSV

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
2915-001-0001-01	3mm_1 3_8_Clr-arg95-Clr-arg95-180#5 en	0.068(#5)	1.22	0.40	0.47	0.2	36
2915-001-0002-01	4mm_1 3_8_Clr-arg95-Clr-arg95-180#5 en	0.068(#5)	1.23	0.38	0.46	0.2	35
2915-001-0003-01	3mm_1 3_8_180#2-arg95-Clr-arg95-180#5 en	0.068(#2, #5)	1.03	0.37	0.45	0.2	38
2915-001-0004-01	4mm_1 3_8_180#2-arg95-Clr-arg95-180#5 en	0.068(#2, #5)	1.05	0.35	0.44	0.2	37
2915-001-0005-01	3mm_1 3_8_Clr-arg95-Clr-arg95-272#5 en	0.042(#5)	1.19	0.31	0.42	0.2	31
2915-001-0006-01	3mm_1 3_8_272#2-arg95-Clr-arg95-272#5 en	0.042(#2, #5)	1.00	0.23	0.37	0.2	31
2915-001-0007-01	3mm_1 3_8_Clr-arg90-Clr-arg90-8071#5 im	0.082(#5)	1.23	0.42	0.47	0.2	37
2915-001-0008-01	3mm_1 3_8_8071#2-arg90-Clr-arg90-8071#5 im	0.082(#2, #5)	1.04	0.38	0.46	0.2	39

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Administrator's Signature:



National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com

