

# Notice of Product Certification

**CERTIFICATION NO.:** 833-012  
**INITIAL CERTIFICATION DATE:** April 12, 2023  
**REVISION DATE:** N/A  
**REPORT NUMBER:** SPL20004-7-C\_VSSH-H  
**SPECIFICATION:** CSA A440.2-19

**COMPANY:** Entreprises Doco, Inc.  
**CODE:** 833-1  
**EXPIRATION DATE:** May 7, 2026  
**PRODUCT SIMULATED BY:** Veridis Solutions  
**AIR LEAKAGE REPORT NO.:** AI-05536-B1

**PRODUCT/SERIES NAME:** Guillotine Simple - Hybride - 9100    **OPERATOR TYPE:** VSSH

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
833-012-0001-01	GL, 3mm_1 1/4_PCI-arg95-PCI-arg95-SG400, iu	0.113(#5)	1.36	0.48	0.53	0.4	37

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
nami@namiinc.com  
namicertification.com