

Notice of Product Certification

CERTIFICATION NO.: 833-017
INITIAL CERTIFICATION DATE: April 12, 2023
REVISION DATE: N/A
REPORT NUMBER: SPL21004-21-C_CSSV-P
SPECIFICATION: CSA A440.2-19

COMPANY: Entreprises Doco, Inc.
CODE: 833-1
EXPIRATION DATE: October 25, 2026
PRODUCT SIMULATED BY: Veridis Solutions
AIR LEAKAGE REPORT NO.: AI-03741-F1 Rev.3

PRODUCT/SERIES NAME: Battant PVC **OPERATOR TYPE:** CSSV

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
833-017-0001-01	GL, 3mm_1 1/4_PCI-arg95-PCI-arg95-SG400, iu	0.113(#5)	1.25	0.43	0.48	0.1	37

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

National Accreditation & Management Institute, Inc.
4794 George Washington Memorial Hwy.
Hayes, VA 23072
Tel.: (804) 684-5124
nami@namiinc.com
namicertification.com