

# Notice of Product Certification

**CERTIFICATION NO.:** 833-018  
**INITIAL CERTIFICATION DATE:** April 12, 2023  
**REVISION DATE:** N/A  
**REPORT NUMBER:** SPL21004-21-C\_LFIXD-P  
**SPECIFICATION:** CSA A440.2-19

**COMPANY:** Entreprises Doco, Inc.  
**CODE:** 833-1  
**EXPIRATION DATE:** November 11, 2027  
**PRODUCT SIMULATED BY:** Veridis Solutions  
**AIR LEAKAGE REPORT NO.:** AI-03741-B1 Rev.3

**PRODUCT/SERIES NAME:** Grand fixe PVC    **OPERATOR TYPE:** FIXD

Product Number	Manufacturer Product Code	Emissivity (Surface #)	U-Factor (Metric)	SHGC(w)	Visible Transmittance (VT)	Air Leakage Average (L75)	Energy Rating
833-018-0001-01	GL_3mm_7/8_PCI-arg95-LOF, iu	0.164(#3)	1.68	0.59	0.60	0.0	37
833-018-0002-01	GL_3mm_7/8_PCI-arg95-SG400, iu	0.113(#3)	1.60	0.56	0.61	0.0	37
833-018-0003-01	GL_3mm_7/8_PCI-arg95-8071, iu	0.082(#3)	1.55	0.56	0.62	0.0	38
833-018-0004-01	GL_3mm_7/8_STCI-arg95-SG400, iu	0.113(#3)	1.60	0.57	0.62	0.0	38
833-018-0005-01	GL_3mm_7/8_STCI-arg95-8071, iu	0.082(#3)	1.55	0.58	0.63	0.0	40
833-018-0006-01	GL_3mm_1 1/4_PCI-arg95-PCI-arg95-LOF, iu	0.164(#5)	1.30	0.54	0.55	0.0	43
833-018-0007-01	GL_3mm_1 1/4_PCI-arg95-PCI-arg95-SG400, iu	0.113(#5)	1.25	0.51	0.56	0.0	42
833-018-0008-01	GL_3mm_1 1/4_PCI-arg95-PCI-arg95-8071, iu	0.082(#5)	1.22	0.51	0.57	0.0	43
833-018-0009-01	GL_3mm_1 1/4_SG400-arg95-PCI-arg95-SG400, iu	0.113(#2, #5)	1.04	0.44	0.54	0.0	43
833-018-0010-01	GL_3mm_1 1/4_8071-arg95-PCI-arg95-8071, iu	0.082(#2, #5)	1.00	0.46	0.56	0.0	45
833-018-0011-01	GL_3mm_1 1/4_SB60-arg95-PCI-arg95-SB60, iu	0.035(#2, #5)	0.95	0.27	0.46	0.0	35
833-018-0012-01	GL_3mm_1 1/4_LOF-arg95-PCI-arg95-LOF, iu	0.164(#2, #5)	1.10	0.48	0.51	0.0	44
833-018-0013-01	GL_3mm_7/8_PCI-arg95-LOF, su	0.164(#3)	1.65	0.59	0.60	0.0	38
833-018-0014-01	GL_3mm_7/8_PCI-arg95-SG400, su	0.113(#3)	1.58	0.55	0.61	0.0	37
833-018-0015-01	GL_3mm_7/8_PCI-arg95-8071, su	0.082(#3)	1.53	0.56	0.62	0.0	39
833-018-0016-01	GL_3mm_7/8_STCI-arg95-SG400, su	0.113(#3)	1.58	0.57	0.62	0.0	38
833-018-0017-01	GL_3mm_7/8_STCI-arg95-8071, su	0.082(#3)	1.53	0.58	0.63	0.0	40
833-018-0018-01	GL_3mm_1 1/4_PCI-arg95-PCI-arg95-LOF, su	0.164(#5)	1.26	0.54	0.55	0.0	44
833-018-0019-01	GL_3mm_1 1/4_PCI-arg95-PCI-arg95-SG400, su	0.113(#5)	1.21	0.51	0.56	0.0	43
833-018-0020-01	GL_3mm_1 1/4_PCI-arg95-PCI-arg95-8071, su	0.082(#5)	1.18	0.51	0.57	0.0	44
833-018-0021-01	GL_3mm_1 1/4_SG400-arg95-PCI-arg95-SG400, su	0.113(#2, #5)	1.00	0.44	0.54	0.0	44
833-018-0022-01	GL_3mm_1 1/4_8071-arg95-PCI-arg95-8071, su	0.082(#2, #5)	0.96	0.46	0.56	0.0	46
833-018-0023-01	GL_3mm_1 1/4_SB60-arg95-PCI-arg95-SB60, su	0.035(#2, #5)	0.91	0.27	0.46	0.0	36
833-018-0024-01	GL_3mm_1 1/4_LOF-arg95-PCI-arg95-LOF, su	0.164(#2, #5)	1.06	0.48	0.51	0.0	45

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).



Administrator's Signature:

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

National Accreditation & Management Institute, Inc.  
4794 George Washington Memorial Hwy.  
Hayes, VA 23072  
Tel.: (804) 684-5124  
nami@namiinc.com  
namicertification.com