NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

NI015748.02	
04/10/2023	
Structural	
Quaker	
031-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DES	CRIPTION
Quaker Window Products		Series "C	200"
504 Highway 63 South		Aluminum Slidin	g Glass Door
Freeburg, MO 65035			
		Configuration Glazing: Insulating G	
	Frame:	W-2210mm(87")	H-2108mm(83")
	Panel:	W-1118mm(44")	H-2038mm(80.25")
	DLO:	W-957mm(37.69")	H-1867mm(73.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-09	Class R-PG50 2210 x 2108 (87 x 83)-SD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By:	Intertek, LLC
Report No:	P5675.02-801-44
Expiration Date:	January 31, 2027

Shi

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com