## NOTICE OF PRODUCT CERTIFICATION



<b>CERTIFICATION NO:</b>
DATE:
<b>CERTIFICATION PROGRAM:</b>
COMPANY:
CODE:

NI015755	
04/03/2023	
Structural	
Heartland	
1018-1	

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit <u>www.namicertification.com</u>. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS		PRODUCT DESC	CRIPTION
Heartland Window Manufacturing	Series "820"		
18517 Highway 57		Vinyl Awning	Window
Aplington, Iowa 50604			
		Configuratio Glazing: Insulating Gla	
	Frame:	W-1245mm(49")	H-838mm(33")
	Sash:	W-1194mm(47")	H-787mm(31")
	DLO:	W-1070mm(42.13")	H-667mm(26.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG40 1245 x 838 (49 x 33)-AP Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By:	Intertek PLC
Report No:	K4663.02-901-44
Expiration Date:	March 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Email: nami@namiinc.com