NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015757

DATE: $\frac{142020707}{04/03/2023}$

CERTIFICATION PROGRAM: Structural

COMPANY: <u>Heartland</u>

CODE: <u>1018-1</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION		
Heartland Window Manufacturing	Series "1400 DTS (Elite)"		
18517 Highway 57	Vinyl Horizontal Sliding Window		
Aplington, Iowa 50604			
	Glazing	Configurationg: Insulating Gla	
	Frame: W-1600	0mm(63")	H-1118mm(44")
	Sash: W-762n	mm(30")	H-1035mm(40.75")
	DLO: W-670r	mm(26.38")	H-953mm(37.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG30 1600 x 1118 (63 x 44)-HS Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek PLC
Report No: L4807.02-901-44
Expiration Date: March 31, 2027

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com