

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015758  
DATE: 04/03/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Heartland  
CODE: 1018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Heartland Window Manufacturing</b> <b>18517 Highway 57</b> <b>Aplington, Iowa 50604</b>	<b>Series "2030 "</b> <b>Vinyl Sliding Glass Door</b>  Configuration: OX Glazing: Insulating Glass (Tempered)  Frame: W-1829mm(72")      H-2083mm(82") Panel: W-924mm(36.38")      H-2022mm(79.63") DLO: W-778mm(30.63")      H-1875mm(73.81")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class R-PG30 1829 x 2083 (72 x 82)-SD</b> <b>Design Pressure: ±1440 Pa (±30 psf)</b> Water Penetration Resistance Test Pressure: 220 Pa (4.60 psf) <b>Canadian Air Infiltration/Exfiltration Level: A2</b>

Product Tested By: Intertek PLC  
Report No: L6273.01-901-44  
Expiration Date: March 31, 2027

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)