

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015760  
**DATE:** 03/22/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Shanghai Mylch  
**CODE:** 2350-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Shanghai Mylch Windows and Doors Manufacturing Co., Ltd. No. 1388 Lin Xian Road Jinshan District, Shanghai, China 201505</b>	<b>Series "UX170" Fiberglass Sliding Glass Door</b>  Configuration: OX Glazing: Insulating Glass (Tempered)  Frame: W-2440mm(96.06") H-2440mm(96.06") Panel: W-1219mm(47.99") H-2340mm(92.13") DLO: W-1033mm(40.67") H-2154mm(84.80")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19</b>	<b>Class CW-PG50 2440 x 2440 (96 x 96)-SD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: Intertek Testing Services Shenzhen Ltd.  
Report No: 221209004SHF-001  
Expiration Date: **December 31, 2026**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)