

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015768
DATE: 04/03/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Elegantview
CODE: 2911-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Elegantview Windows 4492 Commerce Circle SW Atlanta, Georgia 30336	Series "340/740/840" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1524mm(60") H-1524mm(60") DLO: W-1438mm(56.63") H-1435mm(56.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class CW-PG60 1524 x 1524 (60 x 60)-FW Design Pressure: ±2880 Pa (±60 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek PLC
Report No: N3619.02-901-44
Expiration Date: **July 31, 2026**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com