

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015769  
**DATE:** 04/03/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Heartland  
**CODE:** 1018-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Heartland Window Manufacturing</b> <b>18517 Highway 57</b> <b>Aplington, Iowa 50604</b>	<b>Series "810"</b> <b>Vinyl Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-838mm(33")      H-1651mm(65") Sash: W-787mm(31")      H-1600mm(63") DLO: W-664mm(26.13")      H-1476mm(58.13")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b>	<b>Class CW-PG55 838 x 1651 (33 x 65)-C</b> <b>Design Pressure: ±2640 Pa (±55 psf)</b> Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf) <b>Canadian Air Infiltration/Exfiltration Level: A3</b>

Product Tested By: Intertek PLC  
Report No: K4662.02-901-44  
Expiration Date: March 31, 2027

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)