

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015773.02
DATE: 04/11/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Vistamark
CODE: 2165-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| Vistamark Enterprises, LLC. 3581 S Highway 287 Waxahachie, TX 75165 | Series "800" Vinyl Sliding Glass Door Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3594mm(141.50") H-2426mm(95.50") Panel: W-924mm(36.38") H-2343mm(92.25") DLO: W-740mm(29.13") H-2159mm(85") |

| SPECIFICATION | PRODUCT RATING |
|---|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09 | Class LC-PG35 3594 x 2426 (142 x 96)-SD Design Pressure: ± 1680 Pa (± 35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf) Canadian Infiltration/Exfiltration Level: A2 |

Product Tested By: Molimo Architectural Product Testing
Report No: 1696.03-109-12
Expiration Date: April 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com