

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015773.03  
DATE: 04/11/2023  
CERTIFICATION PROGRAM: Structural  
COMPANY: Vistamark  
CODE: 2165-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Vistamark Enterprises, LLC.</b> <b>3581 S Highway 287</b> <b>Waxahachie, TX 75165</b>	<b>Series "800"</b> <b>Vinyl Sliding Glass Door</b>  Configuration: OXO Glazing: Insulating Glass (Tempered)  Frame: W-2743mm(108") H-2426mm(95.50") Panel: W-924mm(36.38") H-2343mm(92.25") DLO: W-740mm(29.13") H-2159mm(85")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class LC-PG35 2743 x 2426 (108 x 96)-SD</b> <b>Design Pressure: ±1680 Pa (±35 psf)</b> Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Molimo Architectural Product Testing  
Report No: 1709.03-109-12  
Expiration Date: **April 30, 2027**

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)