

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015773.04
DATE: 04/11/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Vistamark
CODE: 2165-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Vistamark Enterprises, LLC. 3581 S Highway 287 Waxahachie, TX 75165	Series "800" Vinyl Sliding Glass Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-1816mm(71.50") H-2413mm(95") Panel: W-933mm(36.75") H-2340mm(92.13") DLO: W-743mm(29.25") H-2153mm(84.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG40 1816 x 2413 (72 x 95)-SD Design Pressure: ±1920 Pa (±40 psf) Water Penetration Resistance Test Pressure: 290 Pa (6.06 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Molimo Architectural Product Testing
Report No: 2999.02-109-12
Expiration Date: April 30, 2027

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com