

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015773
DATE: 04/11/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Vistamark
CODE: 2165-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Vistamark Enterprises, LLC. 3581 S Highway 287 Waxahachie, TX 75165	Series "800" Vinyl Sliding Glass Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-2413mm(95") H-2426mm(95.50") Panel: W-1226mm(48.25") H-2343mm(92.25") DLO: W-1041mm(41") H-2159mm(85")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG20 2413 x 2426 (95 x 96)-SD Design Pressure: ± 960 Pa (± 20 psf) Water Penetration Resistance Test Pressure: 330 Pa (6.90 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Molimo Architectural Product Testing
Report No: 1697.06-109-12
Expiration Date: April 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com