

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015774-R2  
DATE: 04/11/2023  
CERTIFICATION PROGRAM: Fire  
COMPANY: 84 Lumber  
CODE: 2201-1  
REVISION DATE: 01/29/2024  
EXPIRATION DATE: 04/30/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>84 Lumber, Inc.</b> <b>4287 Stough Road</b> <b>Concord, NC 28207</b>	<b>20-90 Minute Foam-Filled Steel Fire Door</b> <b>(Hollow Metal/24 or 26 Gauge/Flush or Embossed)</b>  Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations  1/2" Minimum Latch Throw Single or Double Swing Only  <b>Maximum Size: 6'0" x 8'0"</b> <b>(Must refer to listing for size/rating limitations)</b> <b>Minimum Thickness: 1-3/4"</b>

SPECIFICATION	PRODUCT RATING
<b>NFPA 252 (2012)</b> <b>UL 10C (2009/2016)</b> <b>UL 10B (2009)</b> <b>UBC Standard 7-2 (1994/1997)</b> <b>CAN/ULC S104 (2010/2015)</b>	<b>90 Minute-Positive Pressure</b> <b>Without Hose Stream</b> <b>20 Minute-Positive Pressure</b> <b>With Hose Stream</b> <b>(26 Gauge Skin - 3'0" x 7'0" Maximum Size)</b> <b>Category B - Additional Edge-Sealing System</b> <b>Required</b>

TEST REPORT
<b>Intertek EEV No: 100754937MID-001, 100108677COQ-001, 100211525COQ-001</b>

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023