

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015774-R4
DATE: 04/11/2023
CERTIFICATION PROGRAM: Fire
COMPANY: 84 Lumber
CODE: 2201-1
REVISION DATE: 04/16/2026
EXPIRATION DATE: 04/30/2027

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>84 Lumber, Inc. 4287 Stough Road Concord, NC 28207</p>	<p>20-90 Minute Foam-Filled Steel Fire Door (Hollow Metal/24 or 26 Gauge/Flush or Embossed)</p> <p style="text-align: center;">Manufacturer Specific Fire Doors for Single or Double Swing Installation in 20 Minute Locations</p> <p style="text-align: center;">1/2" Minimum Latch Throw Single or Double Swing Only</p> <p style="text-align: center;">Maximum Size: 6'0" x 8'0" (Must refer to listing for size/rating limitations) Minimum Thickness: 1-3/4"</p>

SPECIFICATION	PRODUCT RATING
<p>NFPA 252 (2012) UL 10C (2009/2016) UL 10B (2009) UBC Standard 7-2 (1994/1997) CAN/ULC S104 (2010/2015)</p>	<p>90 Minute-Positive Pressure Without Hose Stream 20 Minute-Positive Pressure With Hose Stream (26 Gauge Skin - 3'0" x 7'0" Maximum Size) Category B - Additional Edge-Sealing System Required</p>

TEST REPORT
<p>Intertek EEV No: 100754937MID-001, 100108677COQ-001, 100211525COQ-001</p>

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
nami@namiinc.com