

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015775
DATE: 04/11/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "W200" Aluminum French Inswing Side Hinged Door Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-2108mm(83") Panel: W-884mm(34.81") H-2032mm(80") DLO: W-713mm(28.06") H-1861mm(73.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-09	Class LC-PG50 1829 x 2108 (72 x 83)-LWSHD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, LLC
Report No: P6755.02-801-44
Expiration Date: **January 31, 2027**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "M.D.", written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com