

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015778.01
DATE: 04/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 2897-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Window Manufacturing, LLC 12820 Industrial Road, Suite A Houston, Texas 77015	Series "9220-PW-T000" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1422mm(56") H-1422mm(56") DLO: W-1305mm(51.38") H-1305mm(51.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG70 1422 x 1422 (56 x 56)-FW Design Pressure: ±3360 Pa (±70 psf) Water Penetration Resistance Test Pressure: 580 Pa (12.12 psf) Canadian Infiltration/Exfiltration Level: Fixed

Product Tested By: Intertek, LLC
Report No: E0250.04-501-44
Expiration Date: April 30, 2027

Administrator's Signature:  _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com