

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015779
DATE: 04/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 2897-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Window Manufacturing, LLC 12820 Industrial Road, Suite A Houston, Texas 77015	Series "9220-HS-T000" Vinyl Horizontal Sliding Window Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1651mm(65") Sash: W-897mm(35.31") H-1594mm(62.75") DLO: W-829mm(32.63") H-1581mm(62.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG25 1829 x 1651 (72 x 65)-HS Design Pressure: ± 1200 Pa (± 25 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, LLC
Report No: E0283.03-501-44
Expiration Date: April 30, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com