

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015779.01
DATE: 04/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 2897-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Window Manufacturing, LLC 12820 Industrial Road, Suite A Houston, Texas 77015	Series "9220-HS-T000" Vinyl Horizontal Sliding Window Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1600mm(63") H-1118mm(44") Sash: W-784mm(30.88") H-1064mm(41.88") DLO: W-713mm(28.06") H-994mm(39.13")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG30 1600 x 1118* (63 x 44*)-HS Design Pressure: 1440 Pa (30 psf) Positive Design Pressure: 2640 Pa (55 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.60 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, LLC
Report No: E0283.03-501-44
Expiration Date: April 30, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com