

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015780.01
DATE: 04/12/2023
CERTIFICATION PROGRAM: Structural
COMPANY: American
CODE: 2897-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
American Window Manufacturing, LLC 12820 Industrial Road, Suite A Houston, Texas 77015	Series "9220-SH-T000" Vinyl Single Hung Window (All Reinforced) Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1118mm(44") H-1905mm(75") Sash: W-1064mm(41.88") H-924mm(36.38") DLO: W-997mm(39.25") H-857mm(33.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class LC-PG50 1118 x 1905 (44 x 75)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, LLC
Report No: E1392.04-501-44
Expiration Date: April 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com