

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015780  
**DATE:** 04/12/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** American  
**CODE:** 2897-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>American Window Manufacturing, LLC</b> <b>12820 Industrial Road, Suite A</b> <b>Houston, Texas 77015</b>	<b>Series "9220-SH-T000"</b> <b>Vinyl Single Hung Window</b> <b>(Meeting Rails Reinforced)</b>  Configuration: O/X Glazing: Insulating Glass (Annealed)  Frame: W-1118mm(44") H-1905mm(75")  Sash: W-1064mm(41.88") H-924mm(36.38")  DLO: W-997mm(39.25") H-857mm(33.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>CSA A440S1-09</b>	<b>Class LC-PG40 1118 x 1905 (44 x 75)-H</b> <b>Design Pressure: <math>\pm 1920</math> Pa (<math>\pm 40</math> psf)</b> <b>Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)</b> <b>Canadian Infiltration/Exfiltration Level: A2</b>

Product Tested By: Intertek, LLC  
Report No: E1392.04-501-44  
Expiration Date: April 30, 2027

Administrator's Signature: 

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)