

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI015781  
**DATE:** 04/12/2023  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Beijing North  
**CODE:** 2905-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Beijing North Tech Group, Ltd.</b> <b>Dongcheng Street, Weifang</b> <b>Shandong, 100130 China</b>	<b>Series "N8200"</b> <b>Aluminum Dual-Action Window &amp;</b> <b>Fixed Window Assembly</b>  Configuration: OX  Glazing: Insulating Glass (Tempered)  Frame: W-2654mm(104.49") H-1850mm(72.83") Panel: W-1154mm(45.43") H-1785mm(70.28") DLO: W-1333mm(52.48") H-1764mm(69.45")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>A440S1-17</b>	<b>Class LC-PG50 2654 x 1850 (104 x 73)-DAW</b> <b>Design Pressure: ±2400 Pa (±50 psf)</b> Water Penetration Resistance Pressure: 400 Pa (8.35 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek - Shanghai  
Report No: 210812008SHF-002  
Expiration Date: April 30, 2027

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124

**Email: [nami@namiinc.com](mailto:nami@namiinc.com)**

