

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015782
DATE: 04/13/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Linea Rossa
CODE: 2749-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Linea Rossa, LLC 1850 Northwest 84th Avenue, Suite 114 Doral, FL 33126	Series "GLR-U28" Aluminum Sliding Glass Door & Lift & Slide System Configuration: OXXXXO Glazing: IG - 1/4" Heat Strengthened Glass/1/4" Heat Strengthened Glass/0.060" Kuraray PVB Interlayer/1/4" Heat Strengthened Glass or Monolithic - 1/4" Heat Strengthened Glass/0.060" Kuraray PVB Interlayer/1/4" Heat Strengthened Glass or IG - 1/4" Heat Strengthened Glass/1/4" Heat Strengthened Glass/0.090" Kuraray PVB Interlayer/1/4" Heat Strengthened Glass or Monolithic - 1/4" Heat Strengthened Glass/0.090" Kuraray PVB Interlayer/1/4" Heat Strengthened Glass Frame: W-8853mm(348.56") H-3048mm(120") Panel: W-1524mm(60") H-2972mm(117") DLO: W-1343mm(52.88") H-2794mm(110")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3830 Pa (±80 psf) Large Missile Impact Rated

Product Tested By: QAI Laboratories
Report No: 13309
Expiration Date: April 30, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com